

MOT Plan

Delray Beach CRA Alleyway 17 & 63

The City requires Advance Notice VMS boards posted 2 weeks prior to the roadway being closed (not the alleys, just when road intersections are closed). Also City requires advance notice of these dates AS AP because to post information to Public.


Shop Dwg. No. 001
MC Job No. 190221.60 Date 07/08/19
Section 01570 Dwg

- FURNISH AS SUBMITTED (FAS)
- FURNISH AS CORRECTED (FAC)
- REVISE AND RESUBMIT (RAR)

Checking of shop drawing is limited to general design and general arrangement only and is not intended to be a verification of compliance with all requirements. Approval shall not relieve the Contractor from the responsibility of details of Design, correct dimensions for proper fitting, Coordination with others, or any other requirements of the Contract.

MATHEWS CONSULTING,
A BAXTER & WOODMAN COMPANY

BY: Aaron Cutler



Continental Construction USA

95 Merrick Way, Suite # 480 - Coral Gables, FL 33134

Phone: (305) 704-7396



**MOT Block 63 Alley
Work within the Alley**

Per FDOT Traffic Control Index 600 existing pedestrian crosswalk to be maintained during all phases of construction



Continental Construction USA

95 Merrick Way, Suite # 480 - Coral Gables, FL 33134
Phone: (305) 704-7396



MOT Block 63 Alley
Sewer/Drainage/Asphalt work on SW 2nd St

Per FDOT Traffic Control Index 600 existing pedestrian crosswalk to be maintained during all phases of construction



Continental Construction USA

95 Merrick Way, Suite # 480 - Coral Gables, FL 33134
Phone: (305) 704-7396



**MOT Block 17 Alley
Work within the Alley**

Per FDOT Traffic Control Index 600 existing pedestrian crosswalk to be maintained during all phases of construction



Continental Construction USA

95 Merrick Way, Suite # 480 - Coral Gables, FL 33134
Phone: (305) 704-7396



**MOT Block 17 Alley
Concrete/Asphalt work on NW 4th St**

Per FDOT Traffic Control Index 600 existing pedestrian crosswalk to be maintained during all phases of construction



Continental Construction USA

95 Merrick Way, Suite # 480 - Coral Gables, FL 33134

Phone: (305) 704-7396



MOT Block 17 Alley

Drainage/Concrete/Asphalt work on NW 3rd St

Per FDOT Traffic Control Index 600 existing pedestrian crosswalk to be maintained during all phases of construction